

Conformity Declaration

Subject: **Fire Safe C13D/S13D 3-piece ball valves**


We herewith certify that the presented valves passed all requirements accordingly ANSI/API STD 607 – 5th Edition 2005. (Identical to ISO 10497-5:2004)
In reference to section 4.4. of this standard the following valve sizes and pressure ratings are qualified:

- a) sizes 1/4" up to 4"
- b) pressure rating ANSI Class 300/400/600, DIN PN40/63/100
- c) all materials listed under table I in ASME B16.34

The above mentioned tests have passed under the surveillance of TÜV Rheinland Taiwan Ltd.

Document: **GF1.1 (TY) FS 08-0035**
Test report: **FT 0864087 dated 22 May 2008**

Yours sincerely,



P. Bogte
Managing Director